

Cs-134	Cs-137	H-3	全α (gross α)	全β (gross β)	Sr-90	Pu-238	Pu-239+240
放射性物質濃度(検出下限値)(Bq/L)(ND※2:不検出) Radioactivity concentration (Lower detection limit) (Bq/L) (ND※2: Not Detectable)							

T-5	2019/4/18 7:13	ND(0.0014) ND(0.0012)	0.0019 0.0021	ND(0.33)		ND(13)			O L
	2019/4/23 8:10	ND(0.0013)	0.0022						O
		ND(0.0013)	0.0033						L
	2019/4/29 6:55	ND(0.0013)	0.0028						O
		ND(0.0012)	0.0036						L
	2019/5/8 7:08	ND(0.0012)	0.0021	ND(0.35)	ND(2.4)	ND(17)	0.0012		O
		ND(0.0012)	0.0022						L
	2019/5/13 7:05	ND(0.0013)	0.0026						O
		ND(0.0012)	0.0022						L
	2019/5/24 6:57	ND(0.00098)	0.0027	ND(0.35)		ND(18)			O
		ND(0.0012)	0.0016						L
	2019/5/27 7:22	ND(0.0013)	0.0028						O
		ND(0.0014)	0.0015						L
	2019/6/3 7:06	ND(0.0013)	0.0031	ND(0.35)	ND(2.0)	ND(17)	0.0012		O
		ND(0.0013)	0.0017						L
	2019/6/14 6:57	ND(0.0011)	0.0022						O
		ND(0.0012)	0.0021						L
	2019/6/18 7:22	ND(0.0013)	0.0026	ND(0.33)		ND(15)			O
ND(0.0013)		0.0018						L	
2019/6/26 7:17	ND(0.0011)	0.0040						O	
	ND(0.0013)	0.0028						L	
2019/7/1 7:15	ND(0.0012)	0.0024	ND(0.34)	ND(2.4)	ND(15)	0.00080		O	
	ND(0.0011)	0.0022						L	
2019/7/11 7:17	ND(0.0011)	0.0026						O	
	ND(0.0012)	0.0028						L	
2019/7/17 7:29	ND(0.0012)	0.0019	ND(0.38)		ND(15)			O	
	ND(0.0013)	0.0029						L	
2019/7/22 7:09	ND(0.0012)	0.0024						O	
	ND(0.0012)	0.0029						L	
2019/7/29 7:19	ND(0.0012)	0.0017						O	
	ND(0.0012)	0.0024						L	
T-D1	2019/4/17 7:53	ND(0.0014)	0.0043	ND(0.35)		ND(14)			O
		ND(0.0012)	0.0040						L
	2019/4/22 7:47	ND(0.0014)	0.0030						O
		ND(0.0013)	0.0031						L
	2019/4/29 7:47	ND(0.0011)	0.0035						O
		ND(0.0013)	0.0054						L
	2019/5/8 8:11	ND(0.0013)	0.0046	ND(0.35)	ND(2.4)	ND(17)	0.0011		O
		ND(0.0013)	0.0048						L
	2019/5/13 7:46	ND(0.0012)	0.0045						O
		ND(0.0010)	0.0038						L
	2019/5/24 7:45	ND(0.0014)	0.0054	0.46		ND(18)			O
		ND(0.0014)	0.0042						L
	2019/5/28 8:00	ND(0.0011)	0.0048						O
		ND(0.0011)	0.0041						L
	2019/6/3 8:14	ND(0.0012)	0.0042	ND(0.35)	ND(2.3)	ND(17)	0.00068		O
		ND(0.0013)	0.0035						L
	2019/6/14 7:51	ND(0.0012)	0.0033						O
		ND(0.0013)	0.0030						L
	2019/6/17 8:04	ND(0.0013)	0.0094	ND(0.35)		ND(15)			O
		ND(0.0013)	0.0087						L
	2019/6/26 8:12	ND(0.0012)	0.0050						O
		ND(0.0013)	0.0047						L
	2019/7/2 7:54	ND(0.0012)	0.0071	ND(0.34)	ND(2.6)	ND(15)	0.00086		O
		ND(0.0014)	0.0058						L
	2019/7/10 7:55	ND(0.0012)	0.0055						O
		ND(0.0012)	0.0027						L
	2019/7/18 8:08	ND(0.0011)	0.0029	ND(0.36)		ND(18)			O
		ND(0.0012)	0.0028						L
2019/7/22 8:06	ND(0.0011)	0.0049						O	
	ND(0.0013)	0.0042						L	
2019/7/29 8:10	ND(0.0011)	0.0047						O	
	ND(0.0012)	0.0043						L	

{ O: 上層(表層~2m) Outer Layer
L: 下層(海底より2~3m上) Lower Layer

Cs-134	Cs-137	H-3	全α (gross α)	全β (gross β)	Sr-90	Pu-238	Pu-239+240
放射性物質濃度(検出下限値)(Bq/L) (ND※2: 不検出) Radioactivity concentration (Lower detection limit) (Bq/L) (ND※2: Not Detectable)							

T-D5	2019/4/17 8:17	ND(0.0011)	0.0073	0.37		ND(14)			O
		ND(0.0012)	0.0054						L
	2019/4/22 8:15	ND(0.0012)	0.0065						O
		ND(0.0014)	0.0054						L
	2019/4/29 8:14	ND(0.0013)	0.0036						O
		ND(0.0014)	0.0045						L
	2019/5/8 8:43	ND(0.0012)	0.0028	ND(0.35)	ND(2.4)	ND(17)	0.0011		O
		ND(0.0013)	0.0040						L
	2019/5/13 8:11	ND(0.0011)	0.0028						O
		ND(0.0012)	0.0038						L
	2019/5/24 8:13	ND(0.0014)	0.0031	0.56		ND(18)			O
		ND(0.0013)	0.0029						L
	2019/5/28 8:31	ND(0.0012)	0.011						O
		ND(0.0013)	0.0046						L
	2019/6/3 8:39	ND(0.0013)	0.0052	ND(0.35)	ND(2.3)	ND(17)	0.0011		O
		ND(0.0014)	0.0032						L
	2019/6/14 8:17	ND(0.0012)	0.0082						O
		ND(0.0013)	0.0033						L
	2019/6/17 8:30	ND(0.0011)	0.0034	ND(0.35)		ND(15)			O
		ND(0.0012)	0.0042						L
2019/6/26 8:41	ND(0.0012)	0.0043						O	
	ND(0.0012)	0.0037						L	
2019/7/2 8:17	ND(0.0012)	0.0059	ND(0.34)	ND(2.6)	ND(15)	0.0014		O	
	ND(0.0012)	0.0023						L	
2019/7/10 8:19	ND(0.0013)	0.0066						O	
	ND(0.0014)	0.0026						L	
2019/7/18 8:33	ND(0.0013)	0.0036	ND(0.36)		ND(18)			O	
	ND(0.0011)	0.0036						L	
2019/7/22 8:32	ND(0.0013)	0.0044						O	
	ND(0.0012)	0.0043						L	
2019/7/29 8:43	ND(0.0012)	0.0041						O	
	ND(0.0012)	0.0037						L	

T-D9	2019/4/18 8:11	ND(0.0013)	0.0075	ND(0.33)		ND(13)			O
		ND(0.0012)	0.0041						L
	2019/4/23 9:16	ND(0.0013)	0.0040						O
		ND(0.0012)	0.0048						L
	2019/4/29 7:37	ND(0.0013)	0.0065						O
		ND(0.0012)	0.0043						L
	2019/5/8 8:14	ND(0.0013)	0.0033	ND(0.35)	ND(2.4)	ND(17)	0.0014		O
		ND(0.0014)	0.0045						L
	2019/5/13 7:45	ND(0.0011)	0.0029						O
		ND(0.0013)	0.0042						L
	2019/5/24 7:40	ND(0.0013)	0.0025	0.51		ND(18)			O
		ND(0.0014)	0.0043						L
	2019/5/27 8:10	ND(0.0014)	0.0075						O
		ND(0.0012)	0.0037						L
	2019/6/3 7:56	ND(0.0012)	0.0068	ND(0.35)	ND(2.0)	ND(17)	0.0010		O
		ND(0.0011)	0.0036						L
	2019/6/14 8:06	0.0014	0.018						O
		ND(0.0011)	0.0042						L
	2019/6/18 8:15	ND(0.0013)	0.0041	0.39		ND(15)			O
		ND(0.0012)	0.0057						L
2019/6/26 8:07	ND(0.0011)	0.0063						O	
	ND(0.0010)	0.0037						L	
2019/7/1 8:51	ND(0.0012)	0.0042	ND(0.34)	ND(2.4)	ND(15)	0.0013		O	
	ND(0.0012)	0.0048						L	
2019/7/11 8:11	ND(0.0011)	0.0046						O	
	ND(0.0012)	0.0030						L	
2019/7/17 8:24	ND(0.0012)	0.0024	ND(0.38)		ND(15)			O	
	ND(0.0012)	0.0038						L	
2019/7/22 7:54	ND(0.0012)	0.0055						O	
	ND(0.0012)	0.0042						L	
2019/7/29 8:03	ND(0.0013)	0.0036						O	
	ND(0.0013)	0.0043						L	

O: 上層(表層~2m) Outer Layer
 L: 下層(海底より2~3m上) Lower Layer

Cs-134

Cs-137

放射性物質濃度(検出下限値)(Bq/L)(ND※2:不検出)
Radioactivity concentration (Lower detection limit) (Bq/L) (ND※2: Not Detectable)

T-11	2019/4/18 8:46	ND(0.0012)	0.0053	O
		ND(0.0014)	0.0045	L
	2019/4/23 9:54	ND(0.0014)	0.0048	O
		ND(0.0010)	0.0062	L
	2019/4/29 8:05	ND(0.0013)	0.0086	O
		ND(0.0014)	0.0037	L
	2019/5/8 8:51	ND(0.0013)	0.0042	O
		ND(0.0014)	0.0045	L
	2019/5/13 8:13	ND(0.0014)	0.0022	O
		0.0012	0.016	L
	2019/5/24 8:09	ND(0.0012)	0.0086	O
		ND(0.0013)	0.0061	L
	2019/5/27 8:41	ND(0.0013)	0.0052	O
		ND(0.0010)	0.0057	L
	2019/6/3 8:27	ND(0.0014)	0.0061	O
		ND(0.0010)	0.0034	L
	2019/6/14 8:39	ND(0.0011)	0.0056	O
		ND(0.0012)	0.0040	L
	2019/6/18 8:48	ND(0.0014)	0.0052	O
		ND(0.0014)	0.0092	L
2019/6/26 8:35	ND(0.0012)	0.0057	O	
	ND(0.0012)	0.0034	L	
2019/7/1 9:20	ND(0.0012)	0.0080	O	
	ND(0.0013)	0.0056	L	
2019/7/11 8:43	ND(0.0012)	0.012	O	
	ND(0.0012)	0.0052	L	
2019/7/17 9:01	ND(0.0013)	0.010	O	
	ND(0.0014)	0.0043	L	
2019/7/22 8:20	ND(0.0013)	0.0055	O	
	ND(0.0013)	0.0057	L	
2019/7/29 8:34	ND(0.0013)	0.0058	O	
	ND(0.0013)	0.0038	L	

T-14	2019/4/17 7:33	ND(0.0014)	0.0049	O
		ND(0.0013)	0.0042	L
	2019/4/22 7:27	ND(0.0013)	0.0031	O
		ND(0.0014)	0.0052	L
	2019/4/29 7:26	ND(0.0010)	0.0040	O
		0.0013	0.0064	L
	2019/5/8 7:25	ND(0.0015)	0.0039	O
		ND(0.0015)	0.0044	L
	2019/5/13 7:26	ND(0.0011)	0.0035	O
		ND(0.0011)	0.0031	L
	2019/5/24 7:21	ND(0.0012)	0.0086	O
		ND(0.0011)	0.0055	L
	2019/5/28 7:33	ND(0.0013)	0.0041	O
		ND(0.0012)	0.0044	L
	2019/6/3 7:37	ND(0.0012)	0.0045	O
		ND(0.0011)	0.0018	L
	2019/6/14 7:26	ND(0.0011)	0.0056	O
		ND(0.0010)	0.0053	L
	2019/6/17 7:44	ND(0.0011)	0.0040	O
		ND(0.0012)	0.0055	L
2019/6/26 7:51	ND(0.0015)	0.0040	O	
	ND(0.0015)	0.0039	L	
2019/7/2 7:27	ND(0.0011)	0.0042	O	
	ND(0.0011)	0.0033	L	
2019/7/10 7:34	ND(0.0011)	0.0037	O	
	ND(0.0012)	0.0028	L	
2019/7/18 7:48	ND(0.0013)	0.0041	O	
	ND(0.0012)	0.0035	L	
2019/7/22 7:46	ND(0.0013)	0.0048	O	
	ND(0.0013)	0.0032	L	
2019/7/29 7:45	ND(0.0011)	0.0042	O	
	ND(0.0013)	0.0040	L	

O: 上層(表層~2m) Outer Layer
L: 下層(海底より2~3m上) Lower Layer

福島第一原子力発電所沿岸海域の海水採取ポイント
 (Seawater sampling points near and around Fukushima Dai-ichi NPP)



* 図中の×は東京電力ホールディングス(株)福島第一原子力発電所を示す。

* The legends × indicate the locations of TEPCO Fukushima Dai-ichi NPP, respectively.